From:	Philip Mudd
To:	Patrick J. Murray; Danny Mapili - WPD-C; Terry Lamb Sr.; Todd Williams
Cc:	LaShaun Queen; Edwin Lopacki; Joshua Hill; Marcus Witowski - WPRA
Subject:	Initial Outfitting, Transition, & Commodities (IOT&C)
Date:	Wednesday, November 02, 2016 11:06:43 AM
Attachments:	Appendix C - CCPP - Union Square - Building Rules.pdf

---

Patrick

- Who is the POC for the 999 Swing Space Building's Lessor or Building Management Company?

Patrick Murray
Vice President, Construction Management
T 202.207.3954
M 202.367.8908
AKRIDGE
Invested.

o What are the requirements for site protection (flooring etc.) during the relocations? Elevator protection is required. Use core board to protect walls and elevator frames, and Masonite on floor tile in common area corridors while moving items (at the loading dock and all pathways on the floor into the suite).

o What are the height & length limitations loading dock, and freight elevator access? Good access to the loading dock and freight elevator. The 1st and 2nd floor are high finish areas; floors will need a lot of protection.

o What are Building hours of operation See the attached CCPP, there are hours M-F 8:00 am to 6:00 pm, and Saturday from 9:00 am to 1:00 pm. (LaShaun, please confirm).

o Who is the POC for coordination with General Contractor (Construction)? Patrick Murray with Akridge, see contact information above.

o electrical contractor will attached furniture whips to systems furniture from the "J-Box's" Need to provide the specification on the furniture electrical requirements so the electrical engineer may review. GC may

install whips, but furniture may need to be installed prior to final inspection.

0 Electrical contractor will be terminated low-voltage both in offices and desk top. GC (structured cabling contractor) may terminate low voltage

at the desk top. Can we get contact information on them?

o What are the limitation on truck size for the loading dock?

Thanks

Phil
Philip Mudd
Federal Energy Regulatory Commission
888 First Street NE 41-72
Washington DC 20426
Work 202-502-6436
Cell 202-641-6001